



# BROWARD COUNTY BOARD OF RULES AND APPEALS

One North University Drive  
Suite 3500-B  
Plantation, Florida 33324

Phone: 954-765-4500  
Fax: 954-765-4504

www.broward.org/codeappeals

## FBC 6<sup>th</sup> Edition (2017) FORMAL INTERPRETATION (#3)

### 2017 Voting Members

#### **Chair**

Mr. Jeffrey Lucas, FM, CFI, CFEI  
Fire Service Professional

#### **Vice-Chair**

Mr. Kenneth B. Wynn  
Representative Disabled Community

Mr. John Famularo,  
Roofing Contractor  
Mrs. Shalanda Giles Nelson,  
General Contractor

Mr. Daniel Lavrich, P.E.  
Structural Engineer

Mr. Daniel Rourke  
Master Plumber

Mr. Gregg D'Attile,  
Mechanical Contractor

Mr. Stephen E. Bailey, P.E.  
Electrical Engineer

Mr. Ron Burr  
Swimming Pool Contractor

Mr. John Sims,  
Master Electrician

VACANT

Consumer Advocate  
Mr. Abbas H. Zackria, CSI  
Architect

Robert A. Kamm, P.E.  
Mechanical Engineer

### 2017 Alternate Board Members

Mr. Jeff Falkanger  
Architect

Mr. Steven Feller, P.E.  
Mechanical Engineer

Mr. Alberto Fernandez,  
General Contractor

Mr. Robert Taylor  
Fire Service

Mr. Gary Elzweig, P.E.  
Structural Engineer

Mr. David Rice, P.E.  
Electrical Engineer

Mr. James Terry,  
Master Plumber

Mr. David Tringo,  
Master Electrician

Mr. William Flett,  
Roofing Contractor

#### **Board Attorney**

Charles M. Kramer, Esq.

#### **Board Administrative Director**

James DiPietro

—Established 1971—

**DATE:** October 12, 2017

**TO:** All Building Officials

**FROM:** James DiPietro, Administrative Director 

**SUBJECT:** Attachments of Ductwork to Air Handling Equipment.

At the meeting of October 12, 2017, BORA approved an interpretation of Section 603.9, Florida Mechanical Code, 6th edition (2017) and section 1601.4.1, FBC, Residential, 6 edition (2017).

These sections state attachment of rigid fibrous glass duct work to air-handling equipment shall be by mechanical attachment and attachment shall be by mechanical fasteners. These sections further define mechanical attachments for air distribution systems as screws, rivets, welds, interlocking joints crimped and rolled, staples, twist in (screw attachment, and compression systems created by bend tabs or screw tabs and flanges or by clinching straps.

Broward County has a long successful history of using UL181 A/P listed pressure-sensitive aluminum foil tape and UL 181 A/M glass fabric and mastic for attaching rigid fibrous glass duct board to cleaned sheet metal equipment flanges in residential applications. North American Insulation Manufacturers Association (NAIMA) is listed in the Reference Standards and Organizations sections of the FMC and FRC. NAIMA's Fibrous Glass Residential Duct Construction Standard states "Connections of fibrous glass duct board to carefully cleaned sheet metal equipment flanges may be made with UL A/P listed pressure-sensitive aluminum foil tape."

#### **Formal Interpretation:**

**The use of UL 181 A/P listed pressure sensitive aluminum tape or UL 181 A/M glass fabric and mastic are acceptable methods of attaching rigid fibrous glass duct work to cleaned sheet metal equipment flanges in residential applications.**

EFFECTIVE DATE: October 20, 2005

RE-ISSUED: October 12, 2017

EFFECTIVE DATE: January 1, 2018

**\*\*\*PLEASE POST AT YOUR PERMIT COUNTER\*\*\*\***

**Page 1 of 1 F.I.#3**