

ENGINEERING

Alessandra Delfico, City Engineer

E: alessandra.delfico@copbfl.com | P: 954.786.4144 | F: 954.786.4028

May 29, 2012

Richard Tornese, PE Broward County Highway Construction and Engineering Division One N. University Drive Box B300 Plantation, FI 33324

RE: Hammondville Road

Dear Mr. Tornese,

The proposed road sections for Hammondville Road have been reviewed and determined to be acceptable to the City. Specifically the plans reflect the following cross sections (attached):

- Overall Roadway Layout for MLK Blvd. (NW 10th Ave. to Dixie Highway.)
 3-ft wide undesignated bike lanes, 10-ft thru lanes, 9-ft wide (parallel) roadside parking and adjacent to CRA or City of Pompano Beach property or wherever the existing/available R-O-W is 94ft or greater (everywhere else provide for 88ft from back of walks)
 - 94-ft R-O-W with 9-ft roadside parking and for 88-ft R-O-W with no roadside parking

Feel free to contact me at 954 786 4144 or alessandra.delfico@copbfl.com if you need additional information.

Sincerely,

Alessandra Delfico, PE

undre Dupo

City Engineer