



BROWARD COUNTY BOARD OF RULES AND APPEALS

1 N. University Drive Suite 3500B
Plantation, Florida 33324

Phone: 954-765-4500
Fax: 954-765-4504
broward.org/CodeAppeals

FBC 6th Edition (2017) FORMAL INTERPRETATION (# 1)

2017 Voting Members

Chair

Mr. Jeffrey Lucas, FM, CFI, CFEI,
Fire Service Professional

Vice-Chair

Mr. Kenneth B. Wynn,
Representative Disabled Community

Mr. John Famularo,
Roofing Contractor
Mrs. Shalanda Giles Nelson,
General Contractor
Mr. Daniel Lavrich, P.E.,
Structural Engineer
Mr. Daniel Rourke,
Master Plumber
Mr. Gregg D'Attile,
Mechanical Contractor
Mr. Stephen E. Bailey, P.E.,
Electrical Engineer
Mr. Ron Burr,
Swimming Pool Contractor
Mr. John Sims,
Master Electrician
Mr. Dennis A. Ulmer,
Consumer Advocate
Mr. Abbas H. Zackria, CSI,
Architect
Robert A. Kamm, P.E.,
Mechanical Engineer

2017 Alternate Board Members

Mr. Jeff Falkanger,
Architect
Mr. Steven Feller, P.E.,
Mechanical Engineer
Mr. Alberto Fernandez,
General Contractor
Mr. Robert Taylor,
Fire Service
Mr. Gary Elzweig, P.E.,
Structural Engineer
Mr. David Rice, P.E.,
Electrical Engineer
Mr. James Terry,
Master Plumber
Mr. David Tringo,
Master Electrician
Mr. William Flett,
Roofing Contractor

Board Attorney

Charles M. Kramer, Esq.

Board Administrative Director

James DiPietro

—ESTABLISHED 1971—

DATE: October 12, 2017
TO: All Building Officials
FROM: James DiPietro, Administrative Director
SUBJECT: Mechanical Code 602.2.1 Materials Exposed within Plenums.

This portion of the Interpretation concerns the residential portion of R-2 occupancies.

At its meeting of October 12, 2017, the Broward County Board of Rules and Appeals approved the following Formal Interpretation.

Section 602.2.1 of the 6th Edition (2017) Florida Mechanical Code requires materials exposed within plenums to be noncombustible or shall have a flame spread index of not more than 25 and a smoke-developed index of not more than 50 when tested in accordance with ASTM E 84-2013A.

CPVC Flowguard Gold Pipe, SDR11 was tested by Southwest Research Institute using a modified ASTM E-84 test methodology in the following sizes.

0.5 inch (nominal) water filled CPVC pipe: SwRI Project No. 01.04017.01.301b [1]
2.0 inch (nominal) water filled CPVC Pipe: SwRI Project No. 01.04017.01.301c [1]
0.5 inch (nominal) empty CPVC Pipe: SwRI Project No. 01.10083.01.158e
0.75 inch (nominal) empty CPVC Pipe: SwRI Project No. 01.10083.01.158f [1]

All four Modified ASTM E-84 Tests showed flame spread indices of not more than 25 and smoke-developed indices of not more than 50.

By accepting these four Modified ASTM-E 84 Tests, the Broward County Board of Rules and Appeals approved the use of CPVC Flowguard Gold Pipe, SDR11 installed in Mechanical Closets and Mechanical Equipment/Appliance Rooms used as plenums in the residential portion of R-2 Occupancies. Approval is limited to 0.5 inch (nominal) thru 2 inch (nominal) water filled CPVC and 0.5 inch (nominal) and 0.75 inch (nominal) empty CPVC pipe.

At its meeting of September 11, 2008 the above Interpretation was expanded to include the following language which applies to both commercial and residential occupancies:

CPVC piping may be accepted for use in plenums in instances where the manufacturers have tested their product with an approved testing agency to an acceptable alternate method to ASTM E-84 – “Standard Test Method for Surface Burning Characteristics of Building Materials”. Evidence must be submitted to the Authority Having Jurisdiction (AHJ) that the piping has a flame spread index of not more than 25 and a smoke developed index of not more than 50 when tested in general accordance with ASTM E-84, 2009 Edition, Pipe can be tested empty or water filled and in various pipe diameters.

EFFECTIVE DATE: OCTOBER 20, 2005
RE-ISSUED: October 12, 2017

EFFECTIVE DATE: January 1, 2018

*****PLEASE POST AT YOUR PERMIT COUNTER*****