



# BROWARD COUNTY BOARD OF RULES AND APPEALS

1 N. University Drive Suite 3500B  
Plantation, Florida 33324

Phone: 954-765-4500  
Fax: 954-765-4504  
broward.org/CodeAppeals

## FBC 6<sup>th</sup> Edition (2017) FORMAL INTERPRETATION (#3)

### 2017 Voting Members

#### **Chair**

Mr. Jeffrey Lucas, FM, CFI, CFEI,  
Fire Service Professional

#### **Vice-Chair**

Mr. Kenneth B. Wynn,  
Representative Disabled Community

Mr. John Famularo,  
Roofing Contractor  
Mrs. Shalanda Giles Nelson,  
General Contractor  
Mr. Daniel Lavrich, P.E.,  
Structural Engineer  
Mr. Daniel Rourke,  
Master Plumber  
Mr. Gregg D'Attile,  
Mechanical Contractor  
Mr. Stephen E. Bailey, P.E.,  
Electrical Engineer  
Mr. Ron Burr,  
Swimming Pool Contractor  
Mr. John Sims,  
Master Electrician  
Mr. Dennis A. Ulmer,  
Consumer Advocate  
Mr. Abbas H. Zackria, CSI,  
Architect  
Robert A. Kamm, P.E.,  
Mechanical Engineer

### 2017 Alternate Board Members

Mr. Jeff Falkanger,  
Architect  
Mr. Steven Feller, P.E.,  
Mechanical Engineer  
Mr. Alberto Fernandez,  
General Contractor  
Mr. Robert Taylor,  
Fire Service  
Mr. Gary Elzweig, P.E.,  
Structural Engineer  
Mr. David Rice, P.E.,  
Electrical Engineer  
Mr. James Terry,  
Master Plumber  
Mr. David Tringo,  
Master Electrician  
Mr. William Flett,  
Roofing Contractor

#### **Board Attorney**

Charles M. Kramer, Esq.

#### **Board Administrative Director**

James DiPietro

—ESTABLISHED 1971—

**DATE:** October 12, 2015

**TO:** All Building Officials

**FROM:** James DiPietro, Administrative Director

**SUBJECT:** Attachments of Ductwork to Air Handling Equipment.

At the meeting of October 12, 2017, BORA approved an interpretation of Section 603.9, Florida Mechanical Code, 6 edition (2017) and section 1601.4.1, FBC, Residential, 6 edition (2017).

These sections state attachment of rigid fibrous glass duct work to air-handling equipment shall be by mechanical attachment and attachment shall be by mechanical fasteners. These sections further define mechanical attachments for air distribution systems as screws, rivets, welds, interlocking joints crimped and rolled, staples, twist in (screw attachment, and compression systems created by bend tabs or screw tabs and flanges or by clinching straps.

Broward County has a long successful history of using UL181 A/P listed pressure-sensitive aluminum foil tape and UL 181 A/M glass fabric and mastic for attaching rigid fibrous glass duct board to cleaned sheet metal equipment flanges in residential applications. North American Insulation Manufacturers Association (NAIMA) is listed in the Reference Standards and Organizations sections of the FMC and FRC. NAIMA's Fibrous Glass Residential Duct Construction Standard states "Connections of fibrous glass duct board to carefully cleaned sheet metal equipment flanges may be made with UL A/P listed pressure-sensitive aluminum foil tape."

#### **Formal Interpretation:**

**The use of UL 181 A/P listed pressure sensitive aluminum tape or UL 181 A/M glass fabric and mastic are acceptable methods of attaching rigid fibrous glass duct work to cleaned sheet metal equipment flanges in residential applications.**

EFFECTIVE DATE: October 20, 2005

RE-ISSUED: October 12, 2017

EFFECTIVE DATE: January 1, 2018

**\*\*\*PLEASE POST AT YOUR PERMIT COUNTER\*\*\***

**Page 1 of 1 F.I.#3**