


**BROWARD COUNTY  
BOARD OF RULES AND APPEALS  
FBC 6<sup>th</sup> Edition (2017)  
FORMAL INTERPRETATION (#14)**

1 N. University Drive Suite 3500B  
Plantation, Florida 33324

Phone: 954-765-4500  
Fax: 954-765-4504  
broward.org/CodeAppeals

**DATE:** October 12, 2017  
**TO:** All Building Officials.  
**FROM:** James DiPietro, Administrative Director   
**SUBJECT:** Interpretation of 6<sup>th</sup> Edition (2017) Florida Building Code  
**Mechanical: 301.15; Building: 453.25.4.3.1, 453.25.4.3.2,  
1609.1.1 Ex. 8; Fuel Gas: 301.10.**

**2017 Voting Members**

**Chair**

Mr. Jeffrey Lucas, FM, CFI, CFEI,  
Fire Service Professional

**Vice-Chair**

Mr. Kenneth B. Wynn,  
Representative Disabled Community

Mr. John Famularo,  
Roofing Contractor  
Mrs. Shalanda Giles Nelson,  
General Contractor  
Mr. Daniel Lavrich, P.E.,  
Structural Engineer  
Mr. Daniel Rourke,  
Master Plumber  
Mr. Gregg D'Attile,  
Mechanical Contractor  
Mr. Stephen E. Bailey, P.E.,  
Electrical Engineer  
Mr. Ron Burr,  
Swimming Pool Contractor  
Mr. John Sims,  
Master Electrician  
Mr. Dennis A. Ulmer,  
Consumer Advocate  
Mr. Abbas H. Zackria, CSI,  
Architect  
Robert A. Kamm, P.E.,  
Mechanical Engineer

**2017 Alternate Board Members**

Mr. Jeff Falkanger,  
Architect  
Mr. Steven Feller, P.E.,  
Mechanical Engineer  
Mr. Alberto Fernandez,  
General Contractor  
Mr. Robert Taylor,  
Fire Service  
Mr. Gary Elzweig, P.E.,  
Structural Engineer  
Mr. David Rice, P.E.,  
Electrical Engineer  
Mr. James Terry,  
Master Plumber  
Mr. David Tringo,  
Master Electrician  
Mr. William Flett,  
Roofing Contractor

**Board Attorney**

Charles M. Kramer, Esq.

**Board Administrative Director**

James DiPietro

—ESTABLISHED 1971—

At its regular meeting of October 12, 2017, the Board of Rules and Appeals approved an interpretation of the following Exception to above sections:

**Wind resistance.** Mechanical equipment, appliances and supports that are exposed to wind shall be designed and installed to resist the wind pressures determined in accordance with the *Florida Building Code, Building*.

**Exception:** Exposed mechanical equipment or appliances fastened to a roof or installed in the ground in compliance with the code using rated stands, platforms, curbs, slabs, walls, or other means are deemed to comply with the winds resistance requirements of the 2007 Florida Building Code, as amended. Further support enclosure of mechanical equipment or appliances is not required by a state or local official having authority to enforce the Florida Building Code.

**Formal interpretation**

1. Mechanical equipment or appliances themselves, are not required to demonstrate compliance with the wind load requirements of the Florida Building Code and no other shielding, sheltering, or reinforcement of the equipment of appliance is required.
2. Notwithstanding Item 1 above, the mechanical equipment or appliances shall be adequately anchored to the rated stands, platforms, curbs, slabs, walls, or other means of support to resist the wind loads of the 2007 Florida Building Code.

**EFFECTIVE DATE:** September 9, 2016

**RE-ISSUED:** October 12, 2017

**EFFECTIVE DATE:** January 1, 2018

\*\*\*PLEASE POST AT YOUR PERMIT COUNTER\*\*\*

Page 1of 1 F.I. #16