



BROWARD COUNTY BOARD OF RULES AND APPEALS

1 N. University Drive, Suite 3500B
Plantation, FL 33324

Phone: 954-765-4500
Fax: 954-765-4504

broward.org/CodeAppeals

FBC 7th EDITION (2020) FORMAL INTERPRETATION (#2)

DATE: July 9, 2020
TO: All Building Officials
FROM: James DiPietro, Administrative Director
SUBJECT: Attachments of Ductwork to Air Handling Equipment

2020 Voting Members

Chair

Mr. Daniel Lavrich,
P.E., S.I., SECB, F.ASCE, F.SEI
Structural Engineer

Vice-Chair

Mr. Stephen E. Bailey, P.E.
Electrical Engineer

Mr. John Famularo,
Roofing Contractor
Mrs. Shalanda Giles Nelson,
General Contractor
Mr. Daniel Rourke
Master Plumber
Mr. Gregg D'Atile,
Mechanical Contractor
Mr. Ron Burr
Swimming Pool Contractor
Mr. John Sims,
Master Electrician
Mr. Dennis A. Ulmer
Consumer Advocate
Mr. Abbas H. Zackria, CSI
Architect
Mr. Robert A. Kamm, P.E.
Mechanical Engineer

Vacant

Representative Disabled Community
Mr. Sergio Pellecer
Fire Service Professional

2020 Alternate Board Members

Mr. Jeff Falkanger
Architect
Mr. Steven Feller, P.E.
Mechanical Engineer
Mr. Alberto Fernandez,
General Contractor
Mr. Robert Taylor
Fire Service
Mr. Gary Elzweig, P.E., F.ASCE
Structural Engineer
Mr. David Rice, P.E.
Electrical Engineer
Mr. James Terry,
Master Plumber
Mr. David Tringo,
Master Electrician
Mr. William Flett,
Roofing Contractor

Board Attorney

Charles M. Kramer, Esq.

Board Administrative Director

James DiPietro

—ESTABLISHED 1971—

At its regularly scheduled meeting of July 9, 2020, the Broward County Board of Rules and Appeals approved an interpretation of Section 603.9, Florida Mechanical Code, 7th edition (2020) and section 1601.4.1, FBC, Residential, 7th edition (2020).

These sections state attachment of rigid fibrous glass duct work to air-handling equipment shall be by mechanical attachment and attachment shall be by mechanical fasteners. These sections further define mechanical attachments for air distribution systems as screws, rivets, welds, interlocking joints crimped and rolled, staples, twist in (screw attachment, and compression systems created by bend tabs or screw tabs and flanges or by clinching straps.

Broward County has a long successful history of using UL181 A/P listed pressure-sensitive aluminum foil tape and UL 181 A/M glass fabric and mastic for attaching rigid fibrous glass duct board to cleaned sheet metal equipment flanges in residential applications. North American Insulation Manufacturers Association (NAIMA) is listed in the Reference Standards and Organizations sections of the FMC and FRC. NAIMA's Fibrous Glass Residential Duct Construction Standard states "Connections of fibrous glass duct board to carefully cleaned sheet metal equipment flanges may be made with UL A/P listed pressure-sensitive aluminum foil tape."

Formal Interpretation:

The use of UL 181 A/P listed pressure sensitive aluminum tape or UL 181 A/M glass fabric and mastic are acceptable methods of attaching rigid fibrous glass duct work to cleaned sheet metal equipment flanges in residential applications.

EFFECTIVE DATE: October 20, 2005
RE-ISSUED DATE: July 9, 2020
EFFECTIVE DATE: December 31, 2020

***** PLEASE POST AT YOUR PERMIT COUNTER *****