



BROWARD COUNTY BOARD OF RULES AND APPEALS

One North University Drive
Suite 3500-B
Plantation, Florida 33324

Phone: 954-765-4500
Fax: 954-765-4504

www.broward.org/codeappeals

FBC 5th Edition (2014)

FORMAL INTERPRETATION (#7)

2015 Voting Members

Mr. Ron Burr
Chair
Mr. Jeffrey Lucas, Deputy Fire Chief
Vice-Chair
Mr. John Famularo,
Roofing Contractor
Mrs. Shalanda Giles Nelson,
General Contractor
Mr. Gary Elzweig, P.E
Structural Engineer
Vacant
Master Plumber
Mr. Gregg D'Attile,
Mechanical Contractor
Mr. Allan Kozich, P.E.
Electrical Engineer
Mr. Kenneth B. Wynn
Representative Disabled Community
Mr. John Sims,
Master Electrician
VACANT
Consumer Advocate
Mr. Abbas H. Zackria, CSI
Architect
VACANT
Mechanical Engineer

2015 Alternate Board Members

Mr. Steven Feller, P.E.
Mechanical Engineer
Mr. Alberto Fernandez,
General Contractor
Mr. Daniel Lavrich, P.E.
Structural Engineer
Assistant Chief Jeff Moral, CFO
Fire Service
Mr. David Rice, P.E.
Electrical Engineer
VACANT
Master Plumber
Mr. David Tringo,
Master Electrician
Mr. William Flett,
Roofing Contractor
VACANT
Architect

Board Attorney
Charles M. Kramer, Esq.

Board Administrative Director
James DiPietro

—ESTABLISHED 1971—

DATE: May 18, 2015

TO: All Building Officials

FROM: James DiPietro

Administrative Director

**SUBJECT: Installation of 100% Wireless Network Low Voltage
Alarm Systems.**

At its regular meeting of May 14, 2015, the Board of Rules and Appeals approved an interpretation regarding 100% Wireless Network Low Voltage Alarm Systems, as follows.

INSTALLATION OF 100% WIRELESS NETWORK LOW VOLTAGE ALARM SYSTEMS, AND ANCILLARY COMPONENTS OR EQUIPMENT ATTACHED TO SUCH A SYSTEM, INCLUDING, BUT NOT LIMITED TO HOME-AUTOMATION EQUIPMENT, THERMOSTATS, AND VIDEO CAMERAS DOES NOT REQUIRE A PERMIT. THIS INTERPRETATION DOES NOT APPLY TO THE INSTALLATION OR REPLACEMENT OF A FIRE ALARM IF A PLAN REVIEW IS REQUIRED.

EFFECTIVE DATE: January 10, 2014

RE-ISSUED: May 14, 2015

EFFECTIVE DATE: June 30, 2015

******PLEASE POST AT YOUR PERMIT COUNTER******