

BROWARD COUNTY BOARD OF RULES AND APPEALS

One North University Drive
Suite 3500-B
Plantation, Florida 33324

Phone: 954-765-4500
Fax: 954-765-4504

www.broward.org/codeappeals

FBC 5th Edition (2014) **FORMAL INTERPRETATION (#11)**

2015 Voting Members

Mr. Ron Burr
Chair
Mr. Jeffrey Lucas, Deputy Fire Chief
Vice-Chair
Mr. John Famularo,
Roofing Contractor
Mrs. Shalanda Giles Nelson,
General Contractor
Mr. Gary Elzweig, P.E
Structural Engineer
VACANT
Master Plumber
Mr. Gregg D'Attile,
Mechanical Contractor
Mr. Allan Kozich, P.E.
Electrical Engineer
Mr. Kenneth B. Wynn
Representative Disabled Community
Mr. John Sims,
Master Electrician
VACANT
Consumer Advocate
Mr. Abbas H. Zackria, CSI
Architect
VACANT
Mechanical Engineer


2015 Alternate Board Members

Mr. Steven Feller, P.E.
Mechanical Engineer
Mr. Alberto Fernandez,
General Contractor
Mr. Daniel Lavrich, P.E.
Structural Engineer
Assistant Chief Jeff Moral, CFO
Fire Service
Mr. David Rice, P.E.
Electrical Engineer
VACANT
Master Plumber
Mr. David Tringo,
Master Electrician
Mr. William Flett,
Roofing Contractor
VACANT
Architect

Board Attorney
Charles M. Kramer, Esq.

Board Administrative Director
James DiPietro

—ESTABLISHED 1971—

DATE: May 18, 2015
TO: All Building Officials
FROM: James DiPietro, Administrative Director 
SUBJECT: Domestic cooking appliances used for commercial purposes.

At its regular meeting of May 14, 2015, the Board of Rules and Appeals approved an interpretation of the following 5th Edition (2014) Florida Building Codes, Mechanical:

1. FBC, Mechanical Section 507.2.3

507.2.3 Domestic cooking appliances used for commercial purposes. Domestic cooking appliances utilized for commercial purposes shall be provided with Type I or Type II hoods as required for the type of appliances and processes in accordance with Sections 507.2, 507.2.1 and 507.2.2.

Formal Interpretation:

Notwithstanding of the frequency or type of use, in occupancies other than single family homes, duplexes, townhouses or apartments; a hood must be provided as required in the 5th Edition (2014) Florida Building Codes, Mechanical Section 507.2.3.

EFFECTIVE DATE: June 30, 2015

*****PLEASE POST AT YOUR PERMIT COUNTER*****