

Lead Tap Sample Analysis and Result Ranking Report

System Name: 1A
PWS: 4060167

Date Submitted to Lab: 7/16/25

Analysis Date: 7/22/25 to 8/20/25

Laboratory Name: Broward County WWS
Lab - ID: E56441
Contact Person: Tom Helton

Lab Analysis Method: EPA 200.8
Method Detection Limit: 0.00034 mg/l
90th Percentile Value: 0.00165 mg/l

Rank	ID No.	Tier	LAB SAMPLE ID	DATE SITE SAMPLED	Lead mg/L
01	21	3	20250717-0031A	7/14/2025	<0.00034
02	01	2	20250716-0030A	7/15/2025	<0.00034
03	24	3	20250716-0033A	7/15/2025	<0.00034
04	02	3	20250716-0036A	7/15/2025	<0.00034
05	05	3	20250717-0036A	7/16/2025	<0.00034
06	29	3	20250717-0035A	7/16/2025	<0.00034
07	06	3	20250717-0032A	7/16/2025	<0.00034
08	30	3	20250717-0033A	7/17/2025	<0.00034
09	09	3	20250717-0038A	7/17/2025	<0.00034
10	16	3	20250721-0052A	7/18/2025	<0.00034
11	18	3	20250718-0041A	7/18/2025	<0.00034
12	41	3	20250716-0039A	7/15/2025	<0.00034
13	14	3	20250717-0029A	7/16/2025	<0.00034
14	28	3	20250718-0043A	7/18/2025	<0.00034
15	34	3	20250717-0037A	7/17/2025	<0.00034
16	38	3	20250717-0039A	7/17/2025	0.00041
17	44	3	20250716-0040A	7/15/2025	0.00043
18	27	3	20250717-0041A	7/17/2025	0.00052
19	48	3	20250717-0030A	7/15/2025	0.00056
20	23	3	20250716-0042A	7/15/2025	0.00063
21	08	3	20250716-0035A	7/15/2025	0.00071
22	49	3	20250716-0041A	7/15/2025	0.00082
23	04	3	20250717-0034A	7/17/2025	0.00087
24	45	3	20250718-0040A	7/18/2025	0.00089
25	25	3	20250716-0034A	7/15/2025	0.00101
26	10	3	20250716-0032A	7/15/2025	0.00120
27	07	3	20250716-0031A	7/15/2025	0.00123
28	12	3	20250717-0040A	7/17/2025	0.00165
29	39	3	20250716-0038A	7/15/2025	0.00183
30	03	3	20250716-0037A	7/14/2025	0.00356
31	36	3	20250718-0042A	7/15/2025	0.00497

Lead Tap Sample Analysis and Result Ranking Report

System Name: 2A
PWS: 4060163

Date Submitted to Lab: 7/25/25
Analysis Date: 8/13/25 to 8/19/25

Laboratory Name: Broward County WWS
Lab - ID: E56441
Contact Person: Tom Helton

Lab Analysis Method: EPA 200.8
Method Detection Limit: 0.00034 mg/l
90th Percentile Value: 0.00316 mg/l

Rank	ID No.	Tier	LAB SAMPLE ID	DATE SITE SAMPLED	Lead mg/L
1	03	1	20250801-0276A	7/26/2025	<0.00034
2	25	2	20250801-0281A	7/28/2025	<0.00034
3	35	3	20250801-0284A	7/31/2025	<0.00034
4	32	2	20250805-0058A	8/1/2025	<0.00034
5	33	3	20250801-0283A	7/31/2025	<0.00034
6	04	1	20250801-0277A	7/31/2025	<0.00034
7	05	1	20250805-0056A	7/31/2025	0.00039
8	29	2	20250728-0035A	7/25/2025	0.00043
9	01	1	20250728-0028A	7/23/2025	0.00045
10	31	2	20250805-0057A	8/1/2025	0.00056
11	09	2	20250728-0030A	7/24/2025	0.00083
12	18	2	20250725-0039A	7/18/2025	0.00087
13	24	2	20250801-0280A	7/25/2025	0.00094
14	12	2	20250725-0040A	7/16/2025	0.00094
15	07	2	20250801-0279A	7/24/2025	0.001
16	13	2	20250725-0033A	7/15/2025	0.00105
17	08	2	20250728-0029A	7/23/2025	0.00114
18	27	2	20250725-0035A	7/15/2025	0.00133
19	28	2	20250728-0034A	7/18/2025	0.00135
20	14	2	20250728-0032A	7/20/2025	0.00179
21	23	2	20250725-0041A	7/20/2025	0.00197
22	06	2	20250801-0278A	7/28/2025	0.00203
23	10	2	20250728-0031A	7/23/2025	0.00217
24	17	2	20250725-0038A	7/22/2025	0.00234
25	16	2	20250725-0037A	7/15/2025	0.00272
26	26	2	20250801-0282A	7/24/2025	0.00283
27	11	2	20250725-0034A	7/16/2025	0.00316
28	22	2	20250728-0033A	7/25/2025	0.00369
29	21	2	20250725-0036A	7/16/2025	0.00390
30	30	2	20250728-0036A	7/18/2025	0.00786

Lead Tap Sample Analysis and Result Ranking Report

System Name: 3A
PWS: 4060165

Date Submitted to Lab: 7/16/25

Analysis Date: 7/22/25 - 9/5/2025

Laboratory Name: Broward County WWS

Lab - ID: E56441

Contact Person: Tom Helton

Lab Analysis Method: EPA 200.8

Method Detection Limit: 0.00034 mg/l

90th Percentile Value: 0.00140 mg/l

Rank	ID NO	TIER	LAB SAMPLE ID	DATE SITE SAMPLED	LEAD mg/L
1	24	4	20250716-0064A	7/15/2025	<0.00034
2	27	4	20250716-0058A	7/15/2025	<0.00034
3	28	4	20250716-0056A	7/15/2025	<0.00034
4	16	3	20250716-0044A	7/16/2025	<0.00034
5	17	3	20250716-0055A	7/16/2025	<0.00034
6	07	2	20250716-0061A	7/16/2025	<0.00034
7	08	3	20250716-0063A	7/16/2025	<0.00034
8	39	4	20250730-0040A	7/29/2025	<0.00034
9	25	4	20250730-0042A	7/30/2025	<0.00034
10	06	2	20250716-0065A	7/15/2025	<0.00034
11	38	4	20250730-0041A	7/30/2025	<0.00034
12	30	4	20250722-0059A	7/15/2025	<0.00034
13	14	3	20250716-0060A	7/16/2025	<0.00034
14	29	4	20250723-0026A	7/23/2025	0.00041
15	33	4	20250730-0044A	7/24/2025	0.00046
16	10	3	20250722-0058A	7/22/2025	0.00047
17	40	4	20250730-0043A	7/27/2025	0.00051
18	12	3	20250718-0047A	7/18/2025	0.00064
19	22	4	20250718-0044A	7/16/2025	0.00066
20	11	3	20250718-0046A	7/18/2025	0.00074
21	05	2	20250716-0066A	7/15/2025	0.00074
22	21	3	20250723-0027A	7/23/2025	0.00084
23	03	1	20250716-0057A	7/16/2025	0.00091
24	35	4	20250719-0024A	7/19/2025	0.00106
25	23	4	20250716-0059A	7/16/2025	0.00118
26	09	3	20250716-0054A	7/16/2025	0.00131
27	15	3	20250723-0028A	7/23/2025	0.00140
28	41	4	20250905-0035A	9/5/2025	0.00183
29	18	3	20250716-0062A	7/15/2025	0.00353
30	37	4	20250730-0045A	7/30/2025	0.00441

Lead Tap Sample Analysis and Result Ranking Report

System Name: 3BC
PWS: 4060162

Date Submitted to Lab: 7/16/25

Analysis Date: 7/22/25 - 8/15/25

Laboratory Name: Broward County WWS
Lab - ID: E56441
Contact Person: Tom Helton

Lab Analysis Method: EPA 200.8
Method Detection Limit: 0.00034 mg/l
90th Percentile Value: 0.00100 mg/l

RANK	ID NO.	TIER	LAB SAMPLE ID	DATE SITE SAMPLED	LEAD mg/L
1	09	3	20250716-0046A	7/15/2025	<0.00034
2	12	3	20250716-0053A	7/15/2025	<0.00034
3	21	3	20250716-0043A	7/16/2025	<0.00034
4	02	3	20250716-0045A	7/16/2025	<0.00034
5	29	3	20250716-0051A	7/16/2025	<0.00034
6	16	3	20250718-0051A	7/17/2025	<0.00034
7	03	3	20250718-0048A	7/18/2025	<0.00034
8	22	3	20250718-0054A	7/18/2025	<0.00034
9	28	3	20250722-0028A	7/18/2025	<0.00034
10	14	3	20250722-0027A	7/20/2025	<0.00034
11	10	3	20250722-0026A	7/21/2025	<0.00034
12	35	3	20250723-0030A	7/23/2025	<0.00034
13	33	3	20250730-0039A	7/30/2025	<0.00034
14	13	3	20250716-0049A	7/16/2025	<0.00034
15	26	3	20250718-0050A	7/16/2025	<0.00034
16	04	3	20250716-0050A	7/16/2025	<0.00034
17	32	3	20250730-0038A	7/30/2025	<0.00034
18	19	3	20250718-0056A	7/18/2025	0.00035
19	24	3	20250718-0058A	7/16/2025	0.00039
20	11	3	20250718-0055A	7/18/2025	0.00041
21	31	3	20250723-0031A	7/23/2025	0.00044
22	01	3	20250722-0025A	7/21/2025	0.00050
23	20	3	20250718-0053A	7/18/2025	0.00051
24	07	3	20250716-0052A	7/15/2025	0.00057
25	06	3	20250718-0057A	7/16/2025	0.00059
26	27	3	20250716-0047A	7/15/2025	0.00082
27	17	3	20250718-0052A	7/17/2025	0.00100
28	15	3	20250716-0048A	7/16/2025	0.00102
29	23	3	20250723-0029A	7/21/2025	0.0012
30	05	3	20250718-0049A	7/17/2025	0.0036