



# BROWARD COUNTY BOARD OF RULES AND APPEALS

## FBC 8<sup>TH</sup> EDITION (2023) FORMAL INTERPRETATION (#10)

1 N. University Drive, Suite 3500B  
Plantation, Florida 33324

Phone: 954-765-4500  
Email: [rulesboard@broward.org](mailto:rulesboard@broward.org)  
[www.broward.org/CodeAppeals](http://www.broward.org/CodeAppeals)

### 2024 Voting Members

**Chair Gregg D'Attile,**  
Mechanical Contractor

**Vice-Chair Ron Burr,**  
Swimming Pool Contractor

**Mr. Stephen Bailey, P.E.,**  
Electrical Engineer

**Mr. John Famularo,**  
Roofing Contractor

**Mrs. Shalanda Giles Nelson,**  
General Contractor

**Mr. Robert A. Kamm, P.E.,**  
Mechanical Engineer

**Mr. Daniel Lavrich, P.E., S.I.,**  
F.A.SCE, F.SEI, Structural Engineer

**Mr. Sergio Pellecer,**  
Fire Service Professional

**Mr. Daniel Rourke,**  
Master Plumber

**Mr. John Sims,**  
Master Electrician

**Mr. Dennis A. Ulmer,**  
Consumer Advocate

**Ms. Lynn E. Wolfson,**  
Disabled Community Representative

**Mr. Abbas H. Zackria, CSI,**  
Architect

### 2024 Alternate Board Members

**Mr. Steven Feller, P.E.,**  
Mechanical Engineer

**Mr. Jeff Falkanger,**  
Architect

**Mr. Alberto Fernandez,**  
General Contractor

**Mr. David Rice, P.E.,**  
Electrical Engineer

**Mr. Robert Taylor,**  
Fire Service Professional

**Mr. James Terry,**  
Master Plumber

**Mr. David Tringo,**  
Master Electrician


**Mr. Derek A. Wassink, P.E., R.A., S.I.,**  
S.T.S.2., Structural Engineer

**VACANT,**  
Roofing Contractor

**Board Attorney**  
Charles M. Kramer, Esq.

**Board Administrative Director**  
Dr. Ana Barbosa

— Established 1971 —

**DATE:** October 12, 2023  
**TO:** All Building Officials  
**FROM:** Dr. Ana Barbosa, Administrative Director   
**SUBJECT:** Ceiling Grid Support for Light Fixtures

Per NEC 410.36, when lighting fixtures are installed in acoustical ceiling grids, they must be securely fastened to the grid. The FBC 5<sup>th</sup> Edition Section 808.1 requires ceiling grids to be installed as per ASTM C635 and ASTM C636. ASTM C635 is the standard for the manufacturer's grid design. ASTM C635 Section 4 explains grid strength types such as light, medium, and heavy-duty, and it also describes the allowable load to be applied to each grid type. ASTM C635 4.3 states the manufacturer is responsible for the design of the specified system. ASTM C636 explains the standard installation requirements. ASTM C636 Section 2.7 specifies the installation of lay-in light fixtures in a grid ceiling. Depending on the load and the type of grid ceiling that is being used, there are three ways to support a lay-in light fixture:

1. By fastening it to the grid per fixture manufacturer's instruction, NEC 410.36(B) and ASTM C636 2.7.1, where installing a light fixture does not compromise the design or strength of the ceiling.
2. By adding additional hanger wires on the grid at the four corners of the grid within 6" of the fixtures where it is determined that more support is needed to support additional loads per ASTM C636 2.7.2.
3. Per ASTM C2636 2.7.2, by independently supporting the fixtures from the grid where the weight of the fixture is determined to be too great for the selected grid to meet the deflection requirement.

### ***Formal Interpretation:***

A supporting detail shall be provided on the Ceiling Grid Plan Pages indicating the method of support of lay-in light fixtures, ceiling fans, ventilator fans, and other ceiling-mounted equipment or fixtures based on the lay-in ceiling system manufacturer's load capabilities for the selected grid used. The detail shall be provided by the design Professional or the manufacturer.

EFFECTIVE DATE: March 10, 2016  
EFFECTIVE DATE: December 31, 2023

**\*\*\* PLEASE POST AT YOUR PERMIT COUNTER \*\*\***