



Public Works Department • Water & Wastewater Services

WATER & WASTEWATER ENGINEERING DIVISION

2555 West Copans Road • Pompano Beach, Florida 33369 • 954-831-0745 • FAX 954-831-0798/0925

GUIDELINE FOR MINIMUM FORCE MAIN SIZING

Date: June 28, 2011

Date Last Issued: January 3, 2005

Date First Issued: January 3, 2005

This document approved by the Broward County Water & Wastewater Services Technical Standards Committee.

A handwritten signature in blue ink, appearing to read "Steven W. Orrick".

Steven W. Orrick, P.E., Chair

The minimum force main size for most circumstances is 6-inches. However, 4-inch force mains will be considered on a case by case basis if two conditions exist:

1. Force main length is less than 1000 feet; and
2. Future flow through the force main (as determined by the Water and Wastewater Engineering Division) is less than 200 ERU (120 gpm peak flow).

If a 4-inch force main is allowed, pumps will be sized to deliver the peak flow or 100 gpm, whichever is greater, in order to have at least 2.5 fps velocity in the force main.